

Licence No. A2008/46

**THE WATER RESOURCES ACT, 1995 – SECTION 19(1)  
LICENCE TO ABSTRACT AND USE WATER**

West Indies Home Contractors

*Name of Licensee*

7 - 9 Harbour Street, Kingston

*Address of Licensee*

is hereby granted a licence to abstract and use water, subject to the provisions of the Water Resources Act and Regulations made there-under and to the terms and conditions herein specified.

*Terms and Conditions of Licence*


1. Water may be abstracted pursuant to this licence only from  
Rodons Well  
(source)  
located at Rodons Pen, Old Harbour, St. Catherine  
such abstraction to be at a rate not exceeding 4,360 cubic metres per day.
2. Water abstracted pursuant to this licence may be used for the following purposes only:  
Domestic purpose(s)
3. Water may be abstracted pursuant to this licence in the following manner only:  
By using a Vertical Turbine/Submersible Pump
4. Within thirty (30) days of the installation of the pump by which water is to be abstracted the licensee shall install on the supply line leading from such pump, a full flow meter (of a type approved by the Authority) for the purpose of measuring the water abstracted.
5. The licensee shall make a monthly return to the Authority of the amount of water abstracted.
6. The licence becomes null and void if within twelve months from the date of the issue thereof, no water is abstracted or used from the approved source pursuant to such licence.
7. The licence shall be valid for a period of 5 years from the date of the issue thereof, subject to the provisions of the Act and Regulations made thereunder relating to its revocation, suspension and variation.

*Additional Terms and Conditions (if any)*

- i. Access for water level measurement (stilling tube) must be installed.
- ii. Pumping water levels must be above sea level.
- iii. Chloride concentration must be less than 250 mg/l
- iv. Water quality to be analysed twice yearly (April and November) for the following parameters and submitted to WRA: sodium, nitrate, chloride, sulphate, total dissolved solids, hardness, faecal coliform, total coliform.

Dated this Twenty-first Project day of November, 2008

Seal

  
 Basil P. Fernandez  
 Secretary,  
 Water Resources Authority